



**Springfield Water and Sewer Commission
WPF Drinking Water Laboratory**

St. James Ave Water Main Break - Water Quality Sampling

Day 1 Sampling						
DEP #	Site Name	Date	Time	Temp (°C)	Bacteria Analysis Day 1	
					Total Coliform	E.Coli
108	1043 Sumner Ave	9/12/2023	20:10	14.1	A ¹	A
113	16 Acres Fire	9/12/2023	20:48	16.3	A	A
114	833 Page Blvd	9/12/2023	21:16	13.2	A	A
119	71 Colton St	9/12/2023	21:43	15.7	A	A
118	Catalina Pump Station	9/12/2023	20:35	14.5	A	A
117	70 Tapley St	9/12/2023	20:59	17.7	A	A
116	1277 Liberty St	9/12/2023	20:37	18.8	A	A
107	Mercy Hospital	9/12/2023	20:02	12.9	A	A
146	Skyridge Pump	9/12/2023	21:31	15.4	A	A
139	Chapin St Pump	9/12/2023	21:46	18.3	A	A
135	ARA Dialysis	9/12/2023	21:08	19.3	A	A

Day 2 Sampling						
DEP #	Site Name	Date	Time	Temp (°C)	Bacteria Analysis Day 2	
					Total Coliform	E.Coli
108	1043 Sumner Ave	9/13/2023	8:00	14.0	A	A
113	16 Acres Fire	9/13/2023	8:38	16.2	A	A
114	833 Page Blvd	9/13/2023	8:54	13.4	A	A
119	71 Colton St	9/13/2023	9:14	16.2	A	A
118	Catalina Pump Station	9/13/2023	8:19	14.2	A	A
117	70 Tapley St	9/13/2023	8:37	17.1	A	A
116	1277 Liberty St	9/13/2023	8:19	19.5	A	A
107	Mercy Hospital	9/13/2023	8:05	13.7	A	A
146	Skyridge Pump	9/13/2023	9:45	15.5	A	A
139	Chapin St Pump	9/13/2023	9:24	17.7	A	A
135	ARA Dialysis	9/13/2023	8:59	18.5	A	A

1. A= absent for bacteria

Susan A. Tower

Susan A. Tower
Laboratory/Regulatory Manager
Laboratory Certification ID: M32951, Expires June 30, 2024