



Springfield Water and Sewer Commission

Industrial Pretreatment Program

Temporary Discharge Permit Allowable Limits		
Polluted Discharge - - 1.4.4 Options of the Executive Director	Daily Maximum (mg/L) *	Monthly Average (mg/L) *
Pollutant		
Total Cadmium	0.69	0.26
Total Chromium	2.77	1.71
Total Copper	3.38	2.07
Total Lead	0.69	0.43
Total Nickel	3.98	2.38
Total Silver	0.43	0.24
Total Zinc	2.61	1.48
Total Cyanide	1.2	0.65
Total Toxic Organics	2.13	
Total Organic Carbon	<10%	
Volatile Organic Compounds	0.5	
Fats, Oils, & Grease (FOG)	100	
LEL	<10%	

Water and Sewer Commission Rules and Regulations 1.5.5 (2) Industrial Wastewaters - - Containing Metals	Daily Maximum (mg/L)	Monthly Average (mg/L)
Pollutant		
Total Copper	16.01	
Total Lead	0.41	
Total Nickel	1.02	
Total Zinc	2.34	

* mg/L = milligram per liter